



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-002-21-LW-2 Valid until December 31, 2023
DENR C.R.No. 074/2018 Valid until September 24, 2021

TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**

Address: **Level 3 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Ave., Diliman, Quezon City**

Contact Person: **Ms. Florisza I. Faustino**

COC Number: **2021-E0025**

Test Report No.: **TR-21E-145**

Date and Time Received: **04 May 2021 @04:00PM**

Sampled By: **ECHEM**

Report Date: **17 May 2021**

Sample ID:	S21-E04-031D	Sampling Date:	04 May 2021
Sample Description:	N5	Sampling Time:	10:59 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:04PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:04PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:04PM	AHP

Sample ID:	S21-E04-032D	Sampling Date:	04 May 2021
Sample Description:	SRCC Boston	Sampling Time:	11:10 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:07PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:07PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:07PM	AHP

Sample ID:	S21-E04-033D	Sampling Date:	04 May 2021
Sample Description:	N4	Sampling Time:	11:15 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:10PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:10PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:10PM	AHP

Sample ID:	S21-E04-034D	Sampling Date:	04 May 2021
Sample Description:	N7	Sampling Time:	11:19 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:13PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:13PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:13PM	AHP

Sample ID:	S21-E04-035D	Sampling Date:	04 May 2021
Sample Description:	Mr. Gregorio Residence	Sampling Time:	11:21 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:16PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:16PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:16PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID: S21-E04-036D

Sample Description: Reservoir 1

Sample Matrix: Drinking Water

Sampling Date: 04 May 2021

Sampling Time: 11:25 AM

Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:19PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:19PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:19PM	AHP

Sample ID: S21-E04-037D

Sample Description: N2

Sample Matrix: Drinking Water

Sampling Date: 04 May 2021

Sampling Time: 11:30 AM

Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:22PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:22PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:22PM	AHP

Sample ID: S21-E04-038D

Sample Description: N1

Sample Matrix: Drinking Water

Sampling Date: 04 May 2021

Sampling Time: 11:34 AM

Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:25PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:25PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:25PM	AHP

Sample ID: S21-E04-039D

Sample Description: N3

Sample Matrix: Drinking Water

Sampling Date: 04 May 2021

Sampling Time: 11:38 AM

Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:28PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:28PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:28PM	AHP

Sample ID: S21-E04-040D

Sample Description: Deepwell 7

Sample Matrix: Drinking Water

Sampling Date: 04 May 2021

Sampling Time: 11:40 AM

Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:31PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:31PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:31PM	AHP

Sample ID: S21-E04-041D

Sample Description: BNC Pawikan

Sample Matrix: Drinking Water

Sampling Date: 04 May 2021

Sampling Time: 11:43 AM

Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:34PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:34PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:34PM	AHP

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID: S21-E04-042D				Sampling Date: 04 May 2021			
Sample Description: BNC Backdoor				Sampling Time: 11:45 AM			
Sample Matrix: Drinking Water				Sampling Location: Anvaya Cove, Morong, Bataan			
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:37PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:37PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:37PM	AHP

Sample ID: S21-E04-043D				Sampling Date: 04 May 2021			
Sample Description: Deepwell 6				Sampling Time: 11:47 AM			
Sample Matrix: Drinking Water				Sampling Location: Anvaya Cove, Morong, Bataan			
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:40PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:40PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:40PM	AHP

Sample ID: S21-E04-044D				Sampling Date: 04 May 2021			
Sample Description: Beechcroft				Sampling Time: 11:50 AM			
Sample Matrix: Drinking Water				Sampling Location: Anvaya Cove, Morong, Bataan			
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:43PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:43PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:43PM	AHP

Sample ID: S21-E04-045D				Sampling Date: 04 May 2021			
Sample Description: Villas				Sampling Time: 11:51 AM			
Sample Matrix: Drinking Water				Sampling Location: Anvaya Cove, Morong, Bataan			
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:46PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:46PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:46PM	AHP

Sample ID: S21-E04-046D				Sampling Date: 04 May 2021			
Sample Description: Deepwell 5				Sampling Time: 11:56 AM			
Sample Matrix: Drinking Water				Sampling Location: Anvaya Cove, Morong, Bataan			
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:49PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:49PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:49PM	AHP

Sample ID: S21-E04-047D				Sampling Date: 04 May 2021			
Sample Description: Sports CenterCommon Area				Sampling Time: 12:00 PM			
Sample Matrix: Drinking Water				Sampling Location: Anvaya Cove, Morong, Bataan			
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:52PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:52PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:52PM	AHP



echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID: **S21-E04-048D**

Sample Description: **Sports Center Kitchen**

Sample Matrix: **Drinking Water**

Sampling Date: **04 May 2021**

Sampling Time: **12:03 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:55PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:55PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:55PM	AHP

Sample ID: **S21-E04-049D**

Sample Description: **Golf Kitchen**

Sample Matrix: **Drinking Water**

Sampling Date: **04 May 2021**

Sampling Time: **12:25 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @07:58PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:58PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @07:58PM	AHP

Sample ID: **S21-E04-050D**

Sample Description: **Caddie**

Sample Matrix: **Drinking Water**

Sampling Date: **04 May 2021**

Sampling Time: **12:27 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @08:01PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:01PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:01PM	AHP

Sample ID: **S21-E04-051D**

Sample Description: **Deepwell 8**

Sample Matrix: **Drinking Water**

Sampling Date: **04 May 2021**

Sampling Time: **12:30 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @08:04PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:04PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:04PM	AHP

Sample ID: **S21-E04-052D**

Sample Description: **Deepwell 9**

Sample Matrix: **Drinking Water**

Sampling Date: **04 May 2021**

Sampling Time: **12:33 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @08:07PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:07PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:07PM	AHP

Sample ID: **S21-E04-053D**

Sample Description: **N9**

Sample Matrix: **Drinking Water**

Sampling Date: **04 May 2021**

Sampling Time: **12:35 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @08:10PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:10PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:10PM	AHP

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: ecchemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID: **S21-E04-054D**Sample Description: **Deepwell 10**Sample Matrix: **Drinking Water**Sampling Date: **04 May 2021**Sampling Time: **12:40 PM**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @08:13PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:13PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:13PM	AHP

Sample ID: **S21-E04-055D**Sample Description: **Deepwell 11**Sample Matrix: **Drinking Water**Sampling Date: **04 May 2021**Sampling Time: **12:43 PM**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @08:16PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:16PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:16PM	AHP

Sample ID: **S21-E04-056D**Sample Description: **SBV Condo**Sample Matrix: **Drinking Water**Sampling Date: **04 May 2021**Sampling Time: **12:48 PM**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @08:19PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:19PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:19PM	AHP

Sample ID: **S21-E04-057D**Sample Description: **N6B**Sample Matrix: **Drinking Water**Sampling Date: **04 May 2021**Sampling Time: **12:50 PM**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @08:22PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:22PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:22PM	AHP

Sample ID: **S21-E04-058D**Sample Description: **Reservoir 2**Sample Matrix: **Drinking Water**Sampling Date: **04 May 2021**Sampling Time: **12:51 PM**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 May 2021 @08:25PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:25PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 May 2021 @08:36PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 May 2021 @08:25PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.



echem

ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Certified by:

[Signature]
Anita H. Pineda, RMT
Medical Technologist, PRC No. 52546

Approved by:

[Signature]
May Ann M. Estavillo, RCh
QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal