



TEST REPORT

Client: **Manila Water Philippine Ventures (MWPV)**
Address: **3rd Floor, One Joroma Place, Congressional Avenue, Quezon City**
Contact Person: **Mr. John Michael M. De Guzman**
COC Number: **2024-L0044**

Test Report No.: **TR-241-147**
Date and Time Received: **03 Dec 2024 @04:00PM**
Sampled By: **ECHEM**
Report Date: **11 Dec 2024**

Sample ID: **S24-L03-028D** Sampling Date: **03 Dec 2024**
Sample Description: **Caddie** Sampling Time: **10:08 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 05:30PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @05:30PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @05:30PM	AHP

Sample ID: **S24-L03-029D** Sampling Date: **03 Dec 2024**
Sample Description: **Deepwell 8** Sampling Time: **10:11 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 05:33PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @05:33PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @05:33PM	AHP

Sample ID: **S24-L03-030D** Sampling Date: **03 Dec 2024**
Sample Description: **Deepwell 9** Sampling Time: **10:16 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 05:36PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @05:36PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @05:36PM	AHP

Sample ID: **S24-L03-031D** Sampling Date: **03 Dec 2024**
Sample Description: **N9** Sampling Time: **10:23 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 05:39PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @05:39PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @05:39PM	AHP

Sample ID: **S24-L03-032D** Sampling Date: **03 Dec 2024**
Sample Description: **SBV Condo** Sampling Time: **10:41 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 05:42PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @05:42PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @05:42PM	AHP

**Echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-507-8753 • 0917-164-2944

Sample ID: **S24-L03-033D**Sampling Date: **03 Dec 2024**Sample Description: **Reservoir 2**Sampling Time: **10:49 AM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 05:45PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @ 05:45PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @ 07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @ 05:45PM	AHP

Sample ID: **S24-L03-034D**Sampling Date: **03 Dec 2024**Sample Description: **Deepwell 10**Sampling Time: **10:55 AM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 05:48PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @ 05:48PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @ 07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @ 05:48PM	AHP

Sample ID: **S24-L03-035D**Sampling Date: **03 Dec 2024**Sample Description: **NGB**Sampling Time: **11:02 AM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 05:51PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @ 05:51PM	AHP
Heterotrophic Plate Count (HPC)	2	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @ 07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @ 05:51PM	AHP

Sample ID: **S24-L03-036D**Sampling Date: **03 Dec 2024**Sample Description: **Deepwell 11**Sampling Time: **11:10 AM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 05:54PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @ 05:54PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @ 07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @ 05:54PM	AHP

Sample ID: **S24-L03-037D**Sampling Date: **03 Dec 2024**Sample Description: **Golf Kitchen**Sampling Time: **10:02 AM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 05:57PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @ 05:57PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @ 07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @ 05:57PM	AHP

Sample ID: **S24-L03-038D**Sampling Date: **03 Dec 2024**Sample Description: **Deepwell 7**Sampling Time: **12:09 PM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:00PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @ 06:00PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @ 07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @ 06:00PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S24-L03-039D
Sample Description: S2A
Sample Matrix: Drinking Water

Sampling Date: 03 Dec 2024
Sampling Time: 12:14 PM
Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:03PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:03PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:03PM	AHP

Sample ID: S24-L03-040D
Sample Description: S1
Sample Matrix: Drinking Water

Sampling Date: 03 Dec 2024
Sampling Time: 12:20 PM
Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:06PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:06PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:06PM	AHP

Sample ID: S24-L03-041D
Sample Description: BNC Pawikan
Sample Matrix: Drinking Water

Sampling Date: 03 Dec 2024
Sampling Time: 12:28 PM
Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:09PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:09PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:09PM	AHP

Sample ID: S24-L03-042D
Sample Description: Villas
Sample Matrix: Drinking Water

Sampling Date: 03 Dec 2024
Sampling Time: 12:35 PM
Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:12PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:12PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:12PM	AHP

Sample ID: S24-L03-043D
Sample Description: BNC Backdoor
Sample Matrix: Drinking Water

Sampling Date: 03 Dec 2024
Sampling Time: 12:43 PM
Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:15PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:15PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:15PM	AHP

Sample ID: S24-L03-044D
Sample Description: Beech Craft
Sample Matrix: Drinking Water

Sampling Date: 03 Dec 2024
Sampling Time: 12:50 PM
Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:18PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:18PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:18PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: cchemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S24-L03-045D		Sampling Date: 03 Dec 2024					
Sample Description: Deepwell 5		Sampling Time: 12:01 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:21PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:21PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:21PM	AHP

Sample ID: S24-L03-046D		Sampling Date: 03 Dec 2024					
Sample Description: Sports Center Common Area		Sampling Time: 12:07 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:24PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:24PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:24PM	AHP

Sample ID: S24-L03-047D		Sampling Date: 03 Dec 2024					
Sample Description: Sports Center Kitchen		Sampling Time: 12:15 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:27PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:27PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:27PM	AHP

Sample ID: S24-L03-048D		Sampling Date: 03 Dec 2024					
Sample Description: N5		Sampling Time: 12:19 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:30PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:30PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:30PM	AHP

Sample ID: S24-L03-049D		Sampling Date: 03 Dec 2024					
Sample Description: Deepwell 13		Sampling Time: 12:24 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:33PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:33PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:33PM	AHP

Sample ID: S24-L03-050D		Sampling Date: 03 Dec 2024					
Sample Description: SPCC Boston		Sampling Time: 12:30 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:36PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:36PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:36PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S24-L03-051D		Sampling Date: 03 Dec 2024					
Sample Description: N4		Sampling Time: 12:36 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:39PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:39PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:39PM	AHP

Sample ID: S24-L03-052D		Sampling Date: 03 Dec 2024					
Sample Description: N7		Sampling Time: 12:43 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:42PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:42PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:42PM	AHP

Sample ID: S24-L03-053D		Sampling Date: 03 Dec 2024					
Sample Description: Tulfo Residence		Sampling Time: 12:46 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:45PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:45PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:45PM	AHP

Sample ID: S24-L03-054D		Sampling Date: 03 Dec 2024					
Sample Description: Reservoir 1		Sampling Time: 12:50 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:48PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:48PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:48PM	AHP

Sample ID: S24-L03-055D		Sampling Date: 03 Dec 2024					
Sample Description: N2		Sampling Time: 12:54 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:51PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:51PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:51PM	AHP

Sample ID: S24-L03-056D		Sampling Date: 03 Dec 2024					
Sample Description: N1		Sampling Time: 01:00 PM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:54PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:54PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @06:54PM	AHP

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com


Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S24-L03-057D			Sampling Date:	03 Dec 2024		
Sample Description:	N3			Sampling Time:	01:05 PM		
Sample Matrix:	Drinking Water			Sampling Location:	Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<i>E.coli</i>	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Dec 2024 @ 06:57PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @ 06:57PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Dec 2024 @ 07:50PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Dec 2024 @ 06:57PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 24th Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:


Aniya H. Pineda, RMT
Chief Microbiologist, PRC No. 52546

Approved by:


May Ann M. Estavillo, RCh
General Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal