



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

DOH Accreditation No. 03-010-2325-LW-2 Valid until December 31, 2025
DENR C.R.No. 074/2023 Valid until June 24, 2026

TEST REPORT

Client: **Manila Water Philippine Ventures, Inc.**

Address: **3rd Floor, UP Town Corporate Center, Katipunan, Quezon City**

Contact Person: **Ms. Florisza Faustino**

COC Number: **2025-F0085**

Test Report No.: **TR-25F-233**

Date and Time Received: **04 Jun 2025 @05:05PM**

Sampled By: **ECHEM**

Report Date: **04 Jul 2025**

Sample ID:	S25-F04-055D	Sampling Date:	04 Jun 2025
Sample Description:	N5	Sampling Time:	08:54 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.74	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectable Odor	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	6.80 @30.0°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.0	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectable Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	152	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	328	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.002	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID:	S25-F04-056D	Sampling Date:	04 Jun 2025
Sample Description:	Deepwell 13	Sampling Time:	09:03 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.59	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectable Odor	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	6.73 @29.1°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.2	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectable Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	150	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	328	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S25-F04-057D		Sampling Date: 04 Jun 2025				
Sample Description: SRCC Boston		Sampling Time: 09:12 AM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.41	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectionable Odor	Threshold Odor Test	05 Jun 2025	CSF
Sulfate	1.4	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectionable Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	150	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	325	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID: S25-F04-058D		Sampling Date: 04 Jun 2025				
Sample Description: N4		Sampling Time: 09:20 AM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.68	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectionable Odor	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	6.70 @28.8°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.2	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectionable Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	139	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	335	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID: S25-F04-059D		Sampling Date: 04 Jun 2025				
Sample Description: N7		Sampling Time: 09:30 AM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.35	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectionable Odor	Threshold Odor Test	05 Jun 2025	CSF
Sulfate	1.8	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectionable Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	137	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	323	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD



echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S25-F04-060D	Sampling Date:	04 Jun 2025
Sample Description:	Tulfo Residence	Sampling Time:	09:38 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.72	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	6.83 @29.9°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.3	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	141	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	322	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID:	S25-F04-061D	Sampling Date:	04 Jun 2025
Sample Description:	Reservoir 1	Sampling Time:	09:46 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	1.5	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.59	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	6.73 @28.7°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.2	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	146	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	327	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	0.01	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID:	S25-F04-062D	Sampling Date:	04 Jun 2025
Sample Description:	N2	Sampling Time:	09:54 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.64	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	6.70 @29.1°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.4	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	148	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	326	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.002	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S25-F04-063D	Sampling Date:	04 Jun 2025			
Sample Description:	N1	Sampling Time:	10:05 AM			
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan			
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.37	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Taste	Threshold Odor Test	05 Jun 2025	CSF
Sulfate	1.0	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	146	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	324	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.002	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID:	S25-F04-064D	Sampling Date:	04 Jun 2025			
Sample Description:	N3	Sampling Time:	10:20 AM			
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan			
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.71	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	0.08	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Taste	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	6.81 @28.7°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.2	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	129	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	323	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID:	S25-F04-065D	Sampling Date:	04 Jun 2025			
Sample Description:	Deepwell 7	Sampling Time:	10:31 AM			
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan			
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	1.5	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH7.26	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Taste	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	7.41 @30.0°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.4	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	125	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	323	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.002	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD



echem

ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S25-F04-066D		Sampling Date: 04 Jun 2025				
Sample Description: S2A		Sampling Time: 10:43 AM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.05	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	05 Jun 2025	CSF
Sulfate	1.2	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	127	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	322	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.002	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID: S25-F04-067D		Sampling Date: 04 Jun 2025				
Sample Description: S1		Sampling Time: 10:52 AM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.32	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	05 Jun 2025	CSF
Sulfate	1.4	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	135	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	328	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.002	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID: S25-F04-068D		Sampling Date: 04 Jun 2025				
Sample Description: BNC Pawikan		Sampling Time: 11:11 AM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.84	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	6.90 @27.8°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.4	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	139	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	327	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.002	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S25-F04-069D		Sampling Date: 04 Jun 2025				
Sample Description: Villas		Sampling Time: 11:19 AM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.91	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	7.01 @28.0°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.3	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	139	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	324	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.002	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID: S25-F04-070D		Sampling Date: 04 Jun 2025				
Sample Description: BNC Back Door		Sampling Time: 11:25 AM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.87	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	7.10 @29.1°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.4	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	146	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	323	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID: S25-F04-071D		Sampling Date: 04 Jun 2025				
Sample Description: Beech Craft		Sampling Time: 11:33 AM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.60	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	6.70 @28.7°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.4	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	150	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	323	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S25-F04-072D			Sampling Date:	04 Jun 2025	
Sample Description:	Deepwell 5			Sampling Time:	11:40 AM	
Sample Matrix:	Drinking Water			Sampling Location:	Anvaya Cove, Morong, Bataan	
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH7.19	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Taste	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	7.20 @29.8°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.3	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	148	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	323	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID:	S25-F04-073D			Sampling Date:	04 Jun 2025	
Sample Description:	Sports Center Common Area			Sampling Time:	11:47 AM	
Sample Matrix:	Drinking Water			Sampling Location:	Anvaya Cove, Morong, Bataan	
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.73	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Taste	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	6.80 @29.1°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.0	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	150	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	330	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	0.01	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID:	S25-F04-074D			Sampling Date:	04 Jun 2025	
Sample Description:	Sports Center Kitchen			Sampling Time:	11:52 AM	
Sample Matrix:	Drinking Water			Sampling Location:	Anvaya Cove, Morong, Bataan	
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.58	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Taste	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	6.74 @29.0°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.4	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	119	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	326	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.002	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S25-F04-075D		Sampling Date: 04 Jun 2025				
Sample Description: Golf Kitchen		Sampling Time: 12:01 PM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.62	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	05 Jun 2025	CSF
Sulfate	1.4	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	117	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	324	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.002	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID: S25-F04-076D		Sampling Date: 04 Jun 2025				
Sample Description: Caddie		Sampling Time: 12:10 PM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.64	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	0.08	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	6.70 @29.1°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.4	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	121	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	323	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.002	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID: S25-F04-077D		Sampling Date: 04 Jun 2025				
Sample Description: Deepwell 8		Sampling Time: 12:18 PM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH7.06	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	0.09	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	7.14 @27.8°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.4	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	129	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	323	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S25-F04-078D				Sampling Date: 04 Jun 2025		
Sample Description: Deepwell 9				Sampling Time: 12:30 PM		
Sample Matrix: Drinking Water				Sampling Location: Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH7.25	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	7.34 @27.1°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.3	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	127	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	321	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID: S25-F04-079D				Sampling Date: 04 Jun 2025		
Sample Description: N9				Sampling Time: 12:38 PM		
Sample Matrix: Drinking Water				Sampling Location: Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.83	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	0.08	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	6.90 @28.8°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.4	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	127	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	334	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID: S25-F04-080D				Sampling Date: 04 Jun 2025		
Sample Description: SBV Condo				Sampling Time: 12:42 PM		
Sample Matrix: Drinking Water				Sampling Location: Anvaya Cove, Morong, Bataan		
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.67	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	6.71 @28.1°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.4	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	127	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	327	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S25-F04-081D	Sampling Date:	04 Jun 2025			
Sample Description:	Reservoir 2	Sampling Time:	12:50 PM			
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan			
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	1.5	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.31	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	7.46 @27.9°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.4	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	125	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	324	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID:	S25-F04-082D	Sampling Date:	04 Jun 2025			
Sample Description:	Deepwell 10	Sampling Time:	12:57 PM			
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan			
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.82	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Color	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	7.10 @27.6°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.0	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	131	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	323	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Sample ID:	S25-F04-083D	Sampling Date:	04 Jun 2025			
Sample Description:	NGB	Sampling Time:	01:07 PM			
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan			
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH6.59	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	<0.06	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectionable Color	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	6.80 @28.8°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.3	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectionable Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	135	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	322	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S25-F04-084D	Sampling Date:	04 Jun 2025			
Sample Description:	Deepwell 11	Sampling Time:	01:15 PM			
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan			
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	1.5	mg/L	0.30-1.50	Colorimetric	04 Jun 2025	MGF
Color, Apparent	<5 @pH7.26	CU	10	Visual Comparison	05 Jun 2025	CSF
Nitrate as NO ₃ -N	0.08	mg/L	50	Colorimetric, Brucine	05 Jun 2025	RRM
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	05 Jun 2025	CSF
pH (on-site)	7.40 @27.8°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sulfate	1.2	mg/L	250	Turbidimetric	11 Jun 2025	KSL
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	05 Jun 2025	CSF
Total Hardness as CaCO ₃	135	mg/L	300	EDTA Titrimetric	06 Jun 2025	SSL
Total Dissolved Solids (TDS)	321	mg/L	600	Gravimetric, Dried @180C	09 Jun 2025	CSF
Turbidity	<1.0	NTU	5	Colorimetric	05 Jun 2025	KSL
Arsenic	0.001	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	20 Jun 2025	KTD
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Iron	<0.009	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Lead	<0.008	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Manganese	<0.003	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 24th Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.
Test Methods for Evaluating Solid Wastes, Vol 1A, USEPA, Third Edition.
ICP - OES = Inductively Coupled Plasma - Optical Emission Spectroscopy

Certified by:

Grace D. Montoya 04 Jul 2025
Lovely Grace D. Montoya, RCh
Laboratory Manager, PRC No. 13651

Approved by:

May Ann M. Estavillo 04 Jul 2025
May Ann M. Estavillo, RCh
General Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: cchemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

DOH Accreditation No.03-010-2325-LW-2 Valid until December 31, 2025
DENR C.R.No. 074/2023 Valid until June 24, 2026

TEST REPORT

Client: **Manila Water Philippine Ventures, Inc.**
Address: **3rd Floor, UP Town Corporate Center, Katipunan, Quezon City**
Contact Person: **Ms. Florisza Faustino**
COC Number: **2025-F0085**

Test Report No.: **TR-25F-233**
Date and Time Received: **04 Jun 2025 @05:05PM**
Sampled By: **ECHEM**
Report Date: **04 Jul 2025**

Sample ID: **S25-F04-055D** Sampling Date: **04 Jun 2025**
Sample Description: **N5** Sampling Time: **08:54 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @06:30PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:30PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:30PM	AHP

Sample ID: **S25-F04-056D** Sampling Date: **04 Jun 2025**
Sample Description: **Deepwell 13** Sampling Time: **09:03 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @06:33PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:33PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:33PM	AHP

Sample ID: **S25-F04-057D** Sampling Date: **04 Jun 2025**
Sample Description: **SRCC Boston** Sampling Time: **09:12 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @06:36PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:36PM	AHP
Heterotrophic Plate Count (HPC)	2	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:36PM	AHP

Sample ID: **S25-F04-058D** Sampling Date: **04 Jun 2025**
Sample Description: **N4** Sampling Time: **09:20 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @06:39PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:39PM	AHP
Heterotrophic Plate Count (HPC)	3	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:39PM	AHP

Sample ID: **S25-F04-059D** Sampling Date: **04 Jun 2025**
Sample Description: **N7** Sampling Time: **09:30 AM**
Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @06:42PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:42PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:42PM	AHP

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S25-F04-060D		Sampling Date: 04 Jun 2025					
Sample Description: Tulfo Residence		Sampling Time: 09:38 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @06:45PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:45PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:45PM	AHP
Sample ID: S25-F04-061D		Sampling Date: 04 Jun 2025					
Sample Description: Reservoir 1		Sampling Time: 09:46 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @06:48PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:48PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:45PM	AHP
Sample ID: S25-F04-062D		Sampling Date: 04 Jun 2025					
Sample Description: N2		Sampling Time: 09:54 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @06:51PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:51PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:51PM	AHP
Sample ID: S25-F04-063D		Sampling Date: 04 Jun 2025					
Sample Description: N1		Sampling Time: 10:05 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @06:54PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:54PM	AHP
Heterotrophic Plate Count (HPC)	5	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:54PM	AHP
Sample ID: S25-F04-064D		Sampling Date: 04 Jun 2025					
Sample Description: N3		Sampling Time: 10:20 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @06:57PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:57PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @06:57PM	AHP
Sample ID: S25-F04-065D		Sampling Date: 04 Jun 2025					
Sample Description: Deepwell 7		Sampling Time: 10:31 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:00PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:00PM	AHP
Heterotrophic Plate Count (HPC)	6	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:00PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S25-F04-066D

Sampling Date: 04 Jun 2025

Sample Description: S2A

Sampling Time: 10:43 AM

Sample Matrix: Drinking Water

Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<i>E.coli</i>	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:03PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:03PM	AHP
Heterotrophic Plate Count (HPC)	14	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:03PM	AHP

Sample ID: S25-F04-067D

Sampling Date: 04 Jun 2025

Sample Description: S1

Sampling Time: 10:52 AM

Sample Matrix: Drinking Water

Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<i>E.coli</i>	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:06PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:06PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:06PM	AHP

Sample ID: S25-F04-068D

Sampling Date: 04 Jun 2025

Sample Description: BNC Pawikan

Sampling Time: 11:11 AM

Sample Matrix: Drinking Water

Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<i>E.coli</i>	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:09PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:09PM	AHP
Heterotrophic Plate Count (HPC)	5	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:09PM	AHP

Sample ID: S25-F04-069D

Sampling Date: 04 Jun 2025

Sample Description: Villas

Sampling Time: 11:19 AM

Sample Matrix: Drinking Water

Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<i>E.coli</i>	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:12PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:12PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:12PM	AHP

Sample ID: S25-F04-070D

Sampling Date: 04 Jun 2025

Sample Description: BNC Back Door

Sampling Time: 11:25 AM

Sample Matrix: Drinking Water

Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<i>E.coli</i>	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:15PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:15PM	AHP
Heterotrophic Plate Count (HPC)	8	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:15PM	AHP

Sample ID: S25-F04-071D

Sampling Date: 04 Jun 2025

Sample Description: Beech Craft

Sampling Time: 11:33 AM

Sample Matrix: Drinking Water

Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<i>E.coli</i>	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:18PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:18PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:18PM	AHP

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Sample ID: **S25-F04-072D**Sampling Date: **04 Jun 2025**Sample Description: **Deepwell 5**Sampling Time: **11:40 AM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:21PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:21PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:21PM	AHP

Sample ID: **S25-F04-073D**Sampling Date: **04 Jun 2025**Sample Description: **Sports Center Common Area**Sampling Time: **11:47 AM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:24PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:24PM	AHP
Heterotrophic Plate Count (HPC)	3	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:24PM	AHP

Sample ID: **S25-F04-074D**Sampling Date: **04 Jun 2025**Sample Description: **Sports Center Kitchen**Sampling Time: **11:52 AM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:27PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:27PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:27PM	AHP

Sample ID: **S25-F04-075D**Sampling Date: **04 Jun 2025**Sample Description: **Golf Kitchen**Sampling Time: **12:01 PM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:30PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:30PM	AHP
Heterotrophic Plate Count (HPC)	2	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:30PM	AHP

Sample ID: **S25-F04-076D**Sampling Date: **04 Jun 2025**Sample Description: **Caddie**Sampling Time: **12:10 PM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:33PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:33PM	AHP
Heterotrophic Plate Count (HPC)	4	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:33PM	AHP

Sample ID: **S25-F04-077D**Sampling Date: **04 Jun 2025**Sample Description: **Deepwell 8**Sampling Time: **12:18 PM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:36PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:36PM	AHP
Heterotrophic Plate Count (HPC)	3	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:36PM	AHP



echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: ecchemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Sample ID: **S25-F04-078D**

Sample Description: **Deepwell 9**

Sample Matrix: **Drinking Water**

Sampling Date: **04 Jun 2025**

Sampling Time: **12:30 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:39PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:39PM	AHP
Heterotrophic Plate Count (HPC)	2	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:39PM	AHP

Sample ID: **S25-F04-079D**

Sample Description: **N9**

Sample Matrix: **Drinking Water**

Sampling Date: **04 Jun 2025**

Sampling Time: **12:38 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:42PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:42PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:42PM	AHP

Sample ID: **S25-F04-080D**

Sample Description: **SBV Condo**

Sample Matrix: **Drinking Water**

Sampling Date: **04 Jun 2025**

Sampling Time: **12:42 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:45PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:45PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:45PM	AHP

Sample ID: **S25-F04-081D**

Sample Description: **Reservoir 2**

Sample Matrix: **Drinking Water**

Sampling Date: **04 Jun 2025**

Sampling Time: **12:50 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:48PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:48PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:48PM	AHP

Sample ID: **S25-F04-082D**

Sample Description: **Deepwell 10**

Sample Matrix: **Drinking Water**

Sampling Date: **04 Jun 2025**

Sampling Time: **12:57 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:51PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:51PM	AHP
Heterotrophic Plate Count (HPC)	6	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:51PM	AHP

Sample ID: **S25-F04-083D**

Sample Description: **NGB**

Sample Matrix: **Drinking Water**

Sampling Date: **04 Jun 2025**

Sampling Time: **01:07 PM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:54PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:54PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:54PM	AHP

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S25-F04-084D				Sampling Date:	04 Jun 2025	
Sample Description:	Deepwell 11				Sampling Time:	01:15 PM	
Sample Matrix:	Drinking Water				Sampling Location:	Anvaya Cove, Morong, Bataan	
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	04 Jun 2025 @07:57PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:57PM	AHP
Heterotrophic Plate Count (HPC)	2	CFU/mL	< 500	PASSED	Pour Plate	04 Jun 2025 @08:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	04 Jun 2025 @07:57PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 24th Edition.
DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:


Anita H. Pineda, RMT
Chief Microbiologist, PRC No. 52546

Approved by:


May Arin M. Estavillo, RCh
General Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: cchemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

DOH Accreditation No.03-010-2325-LW-2 Valid until December 31, 2025

DENR C.R.No. 074/2023 Valid until June 24, 2026

TEST REPORT

Client: **Manila Water Philippine Ventures, Inc.**
Address: **3rd Floor, UP Town Corporate Center, Katipunan, Quezon City**
Contact Person: **Ms. Florisza Faustino**
COC Number: **2025-F0085**

Test Report No.: **TR-25F-233**
Date and Time Received: **04 Jun 2025 @05:05PM**
Sampled By: **ECHEM**
Report Date: **04 Jul 2025**

Sample ID: S25-F04-057D		Sampling Date: 04 Jun 2025				
Sample Description: SRCC Boston		Sampling Time: 09:12 AM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
pH (on-site)	6.47 @29.7°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sample ID: S25-F04-059D		Sampling Date: 04 Jun 2025				
Sample Description: N7		Sampling Time: 09:30 AM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
pH (on-site)	6.43 @29.2°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sample ID: S25-F04-063D		Sampling Date: 04 Jun 2025				
Sample Description: N1		Sampling Time: 10:05 AM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
pH (on-site)	6.43 @29.8°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sample ID: S25-F04-065D		Sampling Date: 04 Jun 2025				
Sample Description: Deepwell 7		Sampling Time: 10:31 AM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Lead	0.02	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	18 Jun 2025	KTD
Sample ID: S25-F04-066D		Sampling Date: 04 Jun 2025				
Sample Description: S2A		Sampling Time: 10:43 AM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
pH (on-site)	6.10 @29.8°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sample ID: S25-F04-067D		Sampling Date: 04 Jun 2025				
Sample Description: S1		Sampling Time: 10:52 AM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
pH (on-site)	6.40 @29.7°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF
Sample ID: S25-F04-075D		Sampling Date: 04 Jun 2025				
Sample Description: Golf Kitchen		Sampling Time: 12:01 PM				
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan				
Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
pH (on-site)	6.46 @29.7°C	---	6.5-8.5	Electrometric	04 Jun 2025	MGF



Echem

ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: cchemenvironmental@gmail.com

Technical: 0917-507-8753 • 0917-164-2944

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 24th Edition.

DOH Administrative Order No. 2017-0010, PNSDW 2017.

Test Methods for Evaluating Solid Wastes, Vol 1A, USEPA, Third Edition.

ICP - OES = Inductively Coupled Plasma - Optical Emission Spectroscopy

Certified by:

Lovely Grace D. Montoya, RCh
04 Jul 2025
Laboratory Manager, PRC No. 13651

Approved by:

May Ann M. Estavillo, RCh
04 Jul 2025
General Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal