

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

DOH Accreditation No.03-002-21-LW-2 Valid until December 31, 2023

DENR C.R.No. 074/2021 Valid until September 28, 2024

TEST REPORTClient: **Manila Water Philippine Ventures (MWPV)**

Address: Level 3, 2nd Phase, BPO Bldg., UP Town Corporate Center, 216 Katipunan Avenue, Diliman, Quezon City

Contact Person: **Ms. Florisza I. Faustino**COC Number: **2023-A0037**Test Report No.: **TR-23A-159B.1**Date and Time Received: **04 Jan 2023 @05:00PM**Sampled By: **ECHEM**Report Date: **17 Jan 2023**

Sample ID:	S23-A04-095D	Sampling Date:	04 Jan 2023
Sample Description:	N5	Sampling Time:	10:10 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	12 Jan 2023	RRM
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.40	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectional Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.41 @27.4°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectional Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	251	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID:	S23-A04-096D	Sampling Date:	04 Jan 2023
Sample Description:	SRCC Boston	Sampling Time:	12:28 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	12 Jan 2023	RRM
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.82	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectional Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.80 @25.8°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectional Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	309	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S23-A04-097D	Sampling Date:	04 Jan 2023
Sample Description:	N4	Sampling Time:	10:15 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	12 Jan 2023	RRM
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.53	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.56 @27.1°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	285	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID:	S23-A04-098D	Sampling Date:	04 Jan 2023
Sample Description:	N7	Sampling Time:	10:21 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	12 Jan 2023	RRM
Chlorine, Residual	0.90	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.40	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.45 @27.4°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	291	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID:	S23-A04-099D	Sampling Date:	04 Jan 2023
Sample Description:	Tulfo Residence	Sampling Time:	10:26 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	12 Jan 2023	RRM
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.43	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.43 @26.9°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	257	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID: **S23-A04-100D**Sampling Date: **04 Jan 2023**Sample Description: **Reservoir 1**Sampling Time: **10:29 AM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	12 Jan 2023	RRM
Chlorine, Residual	1.4	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.40	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectable Odor	TON	No Objectable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.40 @26.7°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectable Taste	FTN	No Objectable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	300	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID: **S23-A04-101D**Sampling Date: **04 Jan 2023**Sample Description: **N2**Sampling Time: **10:33 AM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	12 Jan 2023	RRM
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.41	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectable Odor	TON	No Objectable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.41 @28.1°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectable Taste	FTN	No Objectable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	210	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID: **S23-A04-102D**Sampling Date: **04 Jan 2023**Sample Description: **N1**Sampling Time: **10:36 AM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	12 Jan 2023	RRM
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.42	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectable Odor	TON	No Objectable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.42 @27.7°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectable Taste	FTN	No Objectable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	252	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID: **S23-A04-103D**Sample Description: **N3**Sample Matrix: **Drinking Water**Sampling Date: **04 Jan 2023**Sampling Time: **10:39 AM**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	12 Jan 2023	RRM
Chlorine, Residual	0.90	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.40	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.40 @27.8°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	288	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID: **S23-A04-104D**Sample Description: **Deepwell 7**Sample Matrix: **Drinking Water**Sampling Date: **04 Jan 2023**Sampling Time: **10:42 AM**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	12 Jan 2023	RRM
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.50	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.47 @27.6°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	177	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID: **S23-A04-105D**Sample Description: **BNC Pawikan**Sample Matrix: **Drinking Water**Sampling Date: **04 Jan 2023**Sampling Time: **10:50 AM**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	12 Jan 2023	RRM
Chlorine, Residual	0.90	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.22	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.26 @27.6°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	240	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

**echem****ENVIRONMENTAL TESTING LABORATORY CORPORATION**

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S23-A04-106D	Sampling Date:	04 Jan 2023
Sample Description:	Beechcroft	Sampling Time:	10:58 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	12 Jan 2023	RRM
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.80	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.81 @28.1°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	269	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID:	S23-A04-107D	Sampling Date:	04 Jan 2023
Sample Description:	Villas	Sampling Time:	11:04 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	23 Jan 2023	RRM
Chlorine, Residual	0.90	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.44	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.43 @29.1°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	298	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID:	S23-A04-108D	Sampling Date:	04 Jan 2023
Sample Description:	BNC Backdoor	Sampling Time:	11:11 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	23 Jan 2023	RRM
Chlorine, Residual	0.90	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.45	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.40 @28.9°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	134	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S23-A04-109D	Sampling Date:	04 Jan 2023
Sample Description:	Deepwell 5	Sampling Time:	11:16 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	23 Jan 2023	RRM
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.43	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.43 @29.1°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	187	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID:	S23-A04-110D	Sampling Date:	04 Jan 2023
Sample Description:	Sports Center Common Area	Sampling Time:	11:18 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	23 Jan 2023	RRM
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.40	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.40 @27.1°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	220	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID:	S23-A04-111D	Sampling Date:	04 Jan 2023
Sample Description:	Sports Center Kitchen	Sampling Time:	11:20 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	23 Jan 2023	RRM
Chlorine, Residual	0.8	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.40	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.42 @28.8°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	256	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID: **S23-A04-112D**

Sample Description: **Golf Kitchen**

Sample Matrix: **Drinking Water**

Sampling Date: **04 Jan 2023**

Sampling Time: **11:25 AM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	23 Jan 2023	RRM
Chlorine, Residual	0.90	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.10	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.11 @26.7°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	299	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID: **S23-A04-113D**

Sample Description: **Caddie**

Sample Matrix: **Drinking Water**

Sampling Date: **04 Jan 2023**

Sampling Time: **11:28 AM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	23 Jan 2023	RRM
Chlorine, Residual	0.90	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.11	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.10 @26.6°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	280	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID: **S23-A04-114D**

Sample Description: **Deepwell 8**

Sample Matrix: **Drinking Water**

Sampling Date: **04 Jan 2023**

Sampling Time: **11:35 AM**

Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	23 Jan 2023	RRM
Chlorine, Residual	1.2	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.40	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.40 @29.1°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	191	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM



Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID:	S23-A04-115D	Sampling Date:	04 Jan 2023
Sample Description:	N9	Sampling Time:	11:39 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	23 Jan 2023	RRM
Chlorine, Residual	0.90	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.30	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectional Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.34 @27.7°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectional Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	338	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID:	S23-A04-116D	Sampling Date:	04 Jan 2023
Sample Description:	Deepwell 9	Sampling Time:	11:44 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	23 Jan 2023	RRM
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.40	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectional Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.36 @28.1°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectional Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	276	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID:	S23-A04-117D	Sampling Date:	04 Jan 2023
Sample Description:	Deepwell 11	Sampling Time:	11:50 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	23 Jan 2023	RRM
Chlorine, Residual	1.2	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.46	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectional Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.40 @27.1°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectional Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	296	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM



Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID: **S23-A04-118D**Sample Description: **SBV Condo**Sample Matrix: **Drinking Water**Sampling Date: **04 Jan 2023**Sampling Time: **11:59 AM**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	23 Jan 2023	RRM
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.10	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectional Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.15 @28.1°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectional Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	210	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID: **S23-A04-119D**Sample Description: **N6B**Sample Matrix: **Drinking Water**Sampling Date: **04 Jan 2023**Sampling Time: **12:04 PM**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	12 Jan 2023	RRM
Chlorine, Residual	1	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.10	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectional Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.10 @29.1°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectional Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	389	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID: **S23-A04-120D**Sample Description: **Reservoir 2**Sample Matrix: **Drinking Water**Sampling Date: **04 Jan 2023**Sampling Time: **12:10 PM**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	12 Jan 2023	RRM
Chlorine, Residual	1.4	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.11	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectional Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.11 @29.9°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectional Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	298	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM



Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com

Technical: 0917-164-2927 • 0917-164-2944

Sample ID: **S23-A04-121D**Sampling Date: **04 Jan 2023**Sample Description: **Leemasters International Limited**Sampling Time: **12:20 PM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	12 Jan 2023	RRM
Chlorine, Residual	0.90	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.29	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.29 @25.8°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	326	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID: **S23-A04-122D**Sampling Date: **04 Jan 2023**Sample Description: **S1**Sampling Time: **12:26 PM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	12 Jan 2023	RRM
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.43	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.43 @27.0°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No objectional taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	490	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM

Sample ID: **S23-A04-123D**Sampling Date: **04 Jan 2023**Sample Description: **S2A**Sampling Time: **12:34 PM**Sample Matrix: **Drinking Water**Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Iron	<0.005	mg/L	1.0	Phenanthroline	12 Jan 2023	RRM
Manganese	<0.12	mg/L	0.40	Persulfate	12 Jan 2023	RRM
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	04 Jan 2023	MGF
Color, Apparent	<5 @pH 7.40	CU	---	Visual Comparison	05 Jan 2023	TGG
Nitrate as NO ₃ -N	<0.10	mg/L	50	Colorimetric, Brucine	05 Jan 2023	RRM
Odor	No Objectional Odor	TON	No Objectionable Odor	Threshold Odor Test	05 Jan 2023	TGG
pH (on-site)	7.51 @27.8°C	---	6.5-8.5	Electrometric	04 Jan 2023	MGF
Sulfate	<1.0	mg/L	250	Turbidimetric	09 Jan 2023	RRM
Taste	No Objectional Taste	FTN	No Objectionable Taste	Flavor Threshold Test	05 Jan 2023	TGG
Total Dissolved Solids (TDS)	415	mg/L	600	Gravimetric, Dried @180°C	10 Jan 2023	TGG
Turbidity	<1.0	NTU	5.0	Colorimetric	05 Jan 2023	RRM



echem

ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: 10 Quezon Road, San Isidro, San Simon, Pampanga

Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga

Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795

Email: echemenvironmental@gmail.com


Technical: 0917-164-2927 • 0917-164-2944

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 23rd Edition.

DOH Administrative Order No. 2017-0010, PNSDW 2017.

Certified by:

 17 Jan 2023
Lowel Grace D. Montoya, RCh
Chemist, PRC No. 13651

Approved by:

 17 Jan 2023
May Ann M. Estavillo, RCh
QA/QC Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal