



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

DOH Accreditation No.03-003-2628-LW-2 Valid until December 31, 2028
 DENR C.R.No. 074/2023 Valid until June 24, 2026

TEST REPORT

Client: **Manila Water Philippine Ventures, Inc.**
 Address: **3rd Floor, UP Town Corporate Center, Katipunan, Quezon City**
 Contact Person: **Ms. Florisza Faustino**
 COC Number: **2026-B0032**

Test Report No.: **TR-26B-135**
 Date and Time Received: **03 Feb 2026 @02:47PM**
 Sampled By: **Echem**
 Report Date: **10 Feb 2026**

Sample ID:	S26-B03-014D	Sampling Date:	03 Feb 2026
Sample Description:	N5	Sampling Time:	08:49 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @03:30PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:30PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:30PM	AHP

Sample ID:	S26-B03-015D	Sampling Date:	03 Feb 2026
Sample Description:	Deepwell 13	Sampling Time:	08:53 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @03:33PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:33PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:33PM	AHP

Sample ID:	S26-B03-016D	Sampling Date:	03 Feb 2026
Sample Description:	SRCC Boston	Sampling Time:	09:01 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @03:36PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:36PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:36PM	AHP

Sample ID:	S26-B03-017D	Sampling Date:	03 Feb 2026
Sample Description:	N4	Sampling Time:	09:07 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @03:39PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:39PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:39PM	AHP

Sample ID:	S26-B03-018D	Sampling Date:	03 Feb 2026
Sample Description:	N7	Sampling Time:	09:14 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @03:42PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:42PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:42PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S26-B03-019D	Sampling Date:	03 Feb 2026
Sample Description:	Tulfo Residence	Sampling Time:	09:20 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @03:45PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:45PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:45PM	AHP

Sample ID:	S26-B03-020D	Sampling Date:	03 Feb 2026
Sample Description:	Reservoir 1	Sampling Time:	09:27 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @03:48PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:48PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:48PM	AHP

Sample ID:	S26-B03-021D	Sampling Date:	03 Feb 2026
Sample Description:	N2	Sampling Time:	09:31 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @03:51PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:51PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:51PM	AHP

Sample ID:	S26-B03-022D	Sampling Date:	03 Feb 2026
Sample Description:	N1	Sampling Time:	09:37 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @03:54PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:54PM	AHP
Heterotrophic Plate Count (HPC)	3	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:54PM	AHP

Sample ID:	S26-B03-023D	Sampling Date:	03 Feb 2026
Sample Description:	N3	Sampling Time:	09:41 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @03:57PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:57PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @03:57PM	AHP

Sample ID:	S26-B03-024D	Sampling Date:	03 Feb 2026
Sample Description:	S2A	Sampling Time:	09:49 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:00PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:00PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:00PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S26-B03-025D	Sampling Date:	03 Feb 2026
Sample Description:	S1	Sampling Time:	09:58 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:03PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:03PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:03PM	AHP

Sample ID:	S26-B03-026D	Sampling Date:	03 Feb 2026
Sample Description:	BNC Pawikan	Sampling Time:	10:10 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:06PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:06PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:06PM	AHP

Sample ID:	S26-B03-027D	Sampling Date:	03 Feb 2026
Sample Description:	Villas	Sampling Time:	10:20 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:09PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:09PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:09PM	AHP

Sample ID:	S26-B03-028D	Sampling Date:	03 Feb 2026
Sample Description:	BNC Back Door	Sampling Time:	10:28 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:12PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:12PM	AHP
Heterotrophic Plate Count (HPC)	6	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:12PM	AHP

Sample ID:	S26-B03-029D	Sampling Date:	03 Feb 2026
Sample Description:	Deepwell 5	Sampling Time:	10:32 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:15PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:15PM	AHP
Heterotrophic Plate Count (HPC)	4	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:15PM	AHP

Sample ID:	S26-B03-030D	Sampling Date:	03 Feb 2026
Sample Description:	Sports Center Common Area	Sampling Time:	10:39 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:18PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:18PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:18PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S26-B03-031D	Sampling Date:	03 Feb 2026
Sample Description:	Sports Center Kitchen	Sampling Time:	10:42 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:21PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:21PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:21PM	AHP

Sample ID:	S26-B03-032D	Sampling Date:	03 Feb 2026
Sample Description:	Caddie	Sampling Time:	11:01 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:24PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:24PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:24PM	AHP

Sample ID:	S26-B03-033D	Sampling Date:	03 Feb 2026
Sample Description:	Golf Kitchen	Sampling Time:	11:09 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:27PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:27PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:27PM	AHP

Sample ID:	S26-B03-034D	Sampling Date:	03 Feb 2026
Sample Description:	Deepwell 8	Sampling Time:	11:14 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:30PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:30PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:30PM	AHP

Sample ID:	S26-B03-035D	Sampling Date:	03 Feb 2026
Sample Description:	Deepwell 9	Sampling Time:	11:20 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:33PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:33PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:33PM	AHP

Sample ID:	S26-B03-036D	Sampling Date:	03 Feb 2026
Sample Description:	N9	Sampling Time:	11:26 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:36PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:36PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:36PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S26-B03-037D	Sampling Date:	03 Feb 2026
Sample Description:	SBV Condo	Sampling Time:	11:30 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:39PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:39PM	AHP
Heterotrophic Plate Count (HPC)	3	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:39PM	AHP

Sample ID:	S26-B03-038D	Sampling Date:	03 Feb 2026
Sample Description:	Reservoir 2	Sampling Time:	11:36 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:42PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:42PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:42PM	AHP

Sample ID:	S26-B03-039D	Sampling Date:	03 Feb 2026
Sample Description:	Deepwell 10	Sampling Time:	11:42 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:45PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:45PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:45PM	AHP

Sample ID:	S26-B03-040D	Sampling Date:	03 Feb 2026
Sample Description:	N6B	Sampling Time:	11:50 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:48PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:48PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:48PM	AHP

Sample ID:	S26-B03-041D	Sampling Date:	03 Feb 2026
Sample Description:	Deepwell 11	Sampling Time:	11:56 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	03 Feb 2026 @04:51PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:51PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	03 Feb 2026 @05:10PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	03 Feb 2026 @04:51PM	AHP

Notes & References:

Standard Methods for the Examination of Water and Wastewater, 24th Edition.
 DOH Administrative Order No. 2017-0010, PNSDW 2017.



echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Certified by:

AHP 10 Feb 2024
Anita H. Pineda, RMT
Chief Microbiologist, PRC No. 52546

Approved by:

MAE 10 Feb 2024
May Ann M. Estavillo, RCh
General Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal