



echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

DOH Accreditation No.03-003-2628-LW-2 Valid until December 31, 2028
 DENR C.R.No. 074/2023 Valid until June 24, 2026

TEST REPORT

Client: **Manila Water Philippine Ventures, Inc.** Test Report No.: **TR-26A-199**
 Address: **3rd Floor, UP Town Corporate Center, Katipunan, Quezon City** Date and Time Received: **07 Jan 2026 @05:20PM**
 Contact Person: **Ms. Florisza Faustino** Sampled By: **ECHEM**
 COC Number: **2026-A0075** Report Date: **20 Jan 2026**

Sample ID: **S26-A07-037D** Sampling Date: **07 Jan 2026**
 Sample Description: **N5** Sampling Time: **09:00 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.23	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.36	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	---	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.33 @27.6°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.3	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	---	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	124	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	286	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	<0.004	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Sample ID: **S26-A07-038D** Sampling Date: **07 Jan 2026**
 Sample Description: **Deepwell 13** Sampling Time: **09:09 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.68	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.27	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	---	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.10 @28.8°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.5	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	---	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	120	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	230	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	0.01	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.38	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.30	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
pH (on-site)	7.14 @28.9°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.7	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Total Hardness as CaCO ₃	120	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	245	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	0.009	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.12	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.37	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	6.90 @29.1°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.9	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	124	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	229	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	0.01	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	0.01	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.06	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.38	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.14 @28.9°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.7	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	120	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	257	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	<0.004	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S26-A07-042D	Sampling Date:	07 Jan 2026
Sample Description:	Tulfo Residence	Sampling Time:	09:31 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.13	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.30	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
pH (on-site)	7.21 @28.3°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.7	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Total Hardness as CaCO ₃	126	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	255	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	<0.004	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Sample ID:	S26-A07-043D	Sampling Date:	07 Jan 2026
Sample Description:	Reservoir 1	Sampling Time:	09:38 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	1.5	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.12	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.33	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---		Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.40 @27.7°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.4	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---		Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	128	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	270	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	0.006	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Sample ID:	S26-A07-044D	Sampling Date:	07 Jan 2026
Sample Description:	N2	Sampling Time:	09:43 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.06	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.28	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
pH (on-site)	7.32 @28.0°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.6	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Total Hardness as CaCO ₃	136	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	255	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	0.006	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: cchemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S26-A07-045D	Sampling Date:	07 Jan 2026
Sample Description:	N1	Sampling Time:	09:51 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.05	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.34	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
pH (on-site)	7.28 @28.9°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.0	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Total Hardness as CaCO ₃	256	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	124	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	<0.004	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Sample ID:	S26-A07-046D	Sampling Date:	07 Jan 2026
Sample Description:	N3	Sampling Time:	09:50 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH6.99	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.33	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
pH (on-site)	7.20 @28.8°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.3	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Total Hardness as CaCO ₃	126	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	272	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	<0.004	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Sample ID:	S26-A07-047D	Sampling Date:	07 Jan 2026
Sample Description:	S2A	Sampling Time:	09:59 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.15	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.32	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	---	Threshold Odor Test	07 Jan 2026	SSL
Sulfate	1.7	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	---	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	126	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	258	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	<0.004	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.16	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.44	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Sulfate	1.0	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Total Hardness as CaCO ₃	130	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	261	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	<0.004	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH6.96	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.33	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	No Objectional Test	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.30 @29.7°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.7	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	No Objectional Test	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	132	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	279	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	<0.004	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.16	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.29	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	No Objectional Test	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.28 @29.6°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.7	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	No Objectional Test	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	134	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	224	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	0.006	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	0.03	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.15	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.40	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	As Objectively Test	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.26 @29.8°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.7	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	As Objectively Test	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	130	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	262	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	0.004	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.08	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.38	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	As Objectively Test	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.40 @28.8°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.7	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	As Objectively Test	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	126	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	260	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	0.01	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	0.03	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.14	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.41	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	As Objectively Test	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.10 @28.3°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.7	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	As Objectively Test	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	132	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	231	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	<0.004	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.04	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.33	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.15 @28.5°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	2.3	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	130	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	269	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	<0.004	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.27	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.42	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.14 @28.6°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.3	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	130	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	252	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	<0.004	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.05	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.33	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
pH (on-site)	7.46 @29.6°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.0	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Total Hardness as CaCO ₃	120	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	296	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	<0.004	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: cchemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S26-A07-057D	Sampling Date:	07 Jan 2026
Sample Description:	Deepwell 8	Sampling Time:	11:32 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.15	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.27	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.16 @29.8°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.3	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	130	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	283	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Sample ID:	S26-A07-058D	Sampling Date:	07 Jan 2026
Sample Description:	Deepwell 9	Sampling Time:	11:40 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.22	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.48	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.17 @29.8°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.3	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	134	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	280	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	<0.004	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Sample ID:	S26-A07-059D	Sampling Date:	07 Jan 2026
Sample Description:	N9	Sampling Time:	11:45 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.16	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.24	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.10 @29.9°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.4	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	126	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	271	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	<0.004	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S26-A07-060D	Sampling Date:	07 Jan 2026
Sample Description:	SBV Condo	Sampling Time:	11:49 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	0.80	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.14	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.34	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.14 @29.1°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.3	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	132	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	259	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	0.01	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Sample ID:	S26-A07-061D	Sampling Date:	07 Jan 2026
Sample Description:	Deepwell 10	Sampling Time:	11:54 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH6.98	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.34	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.46 @28.7°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.2	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	132	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	237	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	<0.004	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Sample ID:	S26-A07-062D	Sampling Date:	07 Jan 2026
Sample Description:	N6B	Sampling Time:	12:01 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	1.0	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH6.87	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.38	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.10 @27.7°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.5	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	126	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	268	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S26-A07-063D	Sampling Date: 07 Jan 2026
Sample Description: N6B	Sampling Time: 12:01 PM
Sample Matrix: Drinking Water	Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	2.0	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH7.27	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.41	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.48 @27.8°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.6	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	122	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	245	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	0.009	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Sample ID: S26-A07-064D	Sampling Date: 07 Jan 2026
Sample Description: Reservoir 2	Sampling Time: 12:12 PM
Sample Matrix: Drinking Water	Sampling Location: Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Method	Date Analyzed	Analyst
Chlorine, Residual	1.5	mg/L	0.30-1.50	Colorimetric	07 Jan 2026	MGF
Color, Apparent	<5 @pH6.88	CU	10	Visual Comparison	08 Jan 2026	SSL
Nitrate as NO ₃ -N	0.24	mg/L	50	Colorimetric, Brucine	07 Jan 2026	MCD
Odor	No Objectional Odor	---	No Objectional Odor	Threshold Odor Test	07 Jan 2026	SSL
pH (on-site)	7.40 @27.9°C	---	6.5-8.5	Electrometric	07 Jan 2026	MGF
Sulfate	1.0	mg/L	250	Turbidimetric	13 Jan 2026	KOD
Taste	No Objectional Taste	---	No Objectional Taste	Flavor Threshold Test	07 Jan 2026	SSL
Total Hardness as CaCO ₃	128	mg/L	300	EDTA Titrimetric	08 Jan 2026	KSL
Total Dissolved Solids (TDS)	255	mg/L	600	Gravimetric, Dried @180C	14 Jan 2026	SSL
Turbidity	<1.0	NTU	5	Colorimetric	08 Jan 2026	KOD
Arsenic	<0.004	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Cadmium	<0.001	mg/L	0.003	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Iron	<0.004	mg/L	1.0	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Lead	<0.005	mg/L	0.01	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF
Manganese	<0.001	mg/L	0.40	ICP-OES (SMEWW 3120B/USEPA 6010B)	14 Jan 2026	CSF

Notes & References:

- Standard Methods for the Examination of Water and Wastewater, 24th Edition.
- DOH Administrative Order No. 2017-0010, PNSDW 2017.
- Test Methods for Evaluating Solid Wastes, Vol 1A, USEPA, Third Edition.
- ICP - OES = Inductively Coupled Plasma - Optical Emission Spectroscopy

Certified by:

Grace D. Montoya
 Lovely Grace D. Montoya, RCh
 Laboratory Manager, PRC No. 13651

Approved by:

May Ann M. Estavillo
 May Ann M. Estavillo, RCh
 General Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
 company seal



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

DOH Accreditation No.03-003-2628-LW-2 Valid until December 31, 2028
 DENR C.R.No. 074/2023 Valid until June 24, 2026

TEST REPORT

Client: **Manila Water Philippine Ventures, Inc.**
 Address: **3rd Floor, UP Town Corporate Center, Katipunan, Quezon City**
 Contact Person: **Ms. Florisza Faustino**
 COC Number: **2026-A0075**

Test Report No.: **TR-26A-199**
 Date and Time Received: **07 Jan 2026 @05:20PM**
 Sampled By: **ECEM**
 Report Date: **20 Jan 2026**

Sample ID:	S26-A07-037D	Sampling Date:	07 Jan 2026
Sample Description:	N5	Sampling Time:	09:00 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @06:18PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:18PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:18PM	AHP

Sample ID:	S26-A07-038D	Sampling Date:	07 Jan 2026
Sample Description:	Deepwell 13	Sampling Time:	09:09 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @06:21PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:21PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:21PM	AHP

Sample ID:	S26-A07-039D	Sampling Date:	07 Jan 2026
Sample Description:	SRCC Boston	Sampling Time:	09:14 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @06:24PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:24PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:24PM	AHP

Sample ID:	S26-A07-040D	Sampling Date:	07 Jan 2026
Sample Description:	N4	Sampling Time:	09:21 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @06:27PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:27PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:27PM	AHP

Sample ID:	S26-A07-041D	Sampling Date:	07 Jan 2026
Sample Description:	N7	Sampling Time:	09:27 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @06:30PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:30PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:30PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: S26-A07-042D		Sampling Date: 07 Jan 2026					
Sample Description: Tulfo Residence		Sampling Time: 09:31 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @06:33PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:33PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:33PM	AHP
Sample ID: S26-A07-043D		Sampling Date: 07 Jan 2026					
Sample Description: Reservoir 1		Sampling Time: 09:38 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @06:33PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:33PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:33PM	AHP
Sample ID: S26-A07-044D		Sampling Date: 07 Jan 2026					
Sample Description: N2		Sampling Time: 09:43 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @06:33PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:33PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:33PM	AHP
Sample ID: S26-A07-045D		Sampling Date: 07 Jan 2026					
Sample Description: N1		Sampling Time: 09:51 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @06:42PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:42PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:42PM	AHP
Sample ID: S26-A07-046D		Sampling Date: 07 Jan 2026					
Sample Description: N3		Sampling Time: 09:50 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @06:45PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:45PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:45PM	AHP
Sample ID: S26-A07-047D		Sampling Date: 07 Jan 2026					
Sample Description: S2A		Sampling Time: 09:59 AM					
Sample Matrix: Drinking Water		Sampling Location: Anvaya Cove, Morong, Bataan					
Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @06:45PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:45PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:45PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S26-A07-048D	Sampling Date:	07 Jan 2026
Sample Description:	S1	Sampling Time:	10:08 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @06:51PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:51PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:51PM	AHP

Sample ID:	S26-A07-049D	Sampling Date:	07 Jan 2026
Sample Description:	BNC Pawikan	Sampling Time:	10:22 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @06:54PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:54PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:54PM	AHP

Sample ID:	S26-A07-050D	Sampling Date:	07 Jan 2026
Sample Description:	Villas	Sampling Time:	10:30 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @06:57PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:57PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @06:57PM	AHP

Sample ID:	S26-A07-051D	Sampling Date:	07 Jan 2026
Sample Description:	BNC Back Door	Sampling Time:	10:40 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @07:00PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:00PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:00PM	AHP

Sample ID:	S26-A07-052D	Sampling Date:	07 Jan 2026
Sample Description:	Deepwell 5	Sampling Time:	10:48 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @07:03PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:03PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:03PM	AHP

Sample ID:	S26-A07-053D	Sampling Date:	07 Jan 2026
Sample Description:	Sports Center Common Area	Sampling Time:	10:54 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @07:03PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:03PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:03PM	AHP



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S26-A07-054D	Sampling Date:	07 Jan 2026
Sample Description:	Sports Center Kitchen	Sampling Time:	11:00 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @07:09PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:09PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:09PM	AHP

Sample ID:	S26-A07-055D	Sampling Date:	07 Jan 2026
Sample Description:	Golf Kitchen	Sampling Time:	11:20 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @07:12PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:12PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:12PM	AHP

Sample ID:	S26-A07-056D	Sampling Date:	07 Jan 2026
Sample Description:	Caddie	Sampling Time:	11:26 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @07:15PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:15PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:15PM	AHP

Sample ID:	S26-A07-057D	Sampling Date:	07 Jan 2026
Sample Description:	Deepwell 8	Sampling Time:	11:32 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @07:18PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:18PM	AHP
Heterotrophic Plate Count (HPC)	5	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:18PM	AHP

Sample ID:	S26-A07-058D	Sampling Date:	07 Jan 2026
Sample Description:	Deepwell 9	Sampling Time:	11:40 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @07:21PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:21PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:21PM	AHP

Sample ID:	S26-A07-059D	Sampling Date:	07 Jan 2026
Sample Description:	N9	Sampling Time:	11:45 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @07:21PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:21PM	AHP
Heterotrophic Plate Count (HPC)	1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:21PM	AHP



echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	S26-A07-060D	Sampling Date:	07 Jan 2026
Sample Description:	SBV Condo	Sampling Time:	11:49 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E. coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @07:27PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:27PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:27PM	AHP

Sample ID:	S26-A07-061D	Sampling Date:	07 Jan 2026
Sample Description:	Deepwell 10	Sampling Time:	11:54 AM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E. coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @07:30PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:30PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:30PM	AHP

Sample ID:	S26-A07-062D	Sampling Date:	07 Jan 2026
Sample Description:	N6B	Sampling Time:	12:01 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E. coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @07:33PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:33PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:33PM	AHP

Sample ID:	S26-A07-063D	Sampling Date:	07 Jan 2026
Sample Description:	N6B	Sampling Time:	12:01 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E. coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @07:36PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:36PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:36PM	AHP

Sample ID:	S26-A07-064D	Sampling Date:	07 Jan 2026
Sample Description:	Reservoir 2	Sampling Time:	12:12 PM
Sample Matrix:	Drinking Water	Sampling Location:	Anvaya Cove, Morong, Bataan

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E. coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	07 Jan 2026 @07:39PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:39PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	07 Jan 2026 @07:45PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	07 Jan 2026 @07:39PM	AHP

Notes & References:


Standard Methods for the Examination of Water and Wastewater, 24th Edition.
 DOH Administrative Order No. 2017-0010, PNSDW 2017.



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
Technical: 0917-507-8753 • 0917-164-2944

Certified by:


Arjita H. Pineda, RMT
Chief Microbiologist, PRC No. 52546

Approved by:


May Ann M. Estavillo, RCh
General Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without
company seal