



# Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga  
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga  
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com  
 Technical: 0917-507-8753 • 0917-164-2944

DOH Accreditation No. 03-010-2325-LW-2 Valid until December 31, 2025  
 DENR C.R.No. 074/2023 Valid until June 24, 2026

## TEST REPORT

Client: **Manila Water Philippine Ventures, Inc.**  
 Address: **3rd Floor, UP Town Corporate Center, Katipunan, Quezon City**  
 Contact Person: **Ms. Florisza Faustino**  
 COC Number: **2025-G0037**

Test Report No.: **TR-25G-224**  
 Date and Time Received: **02 Jul 2025 @04:50PM**  
 Sampled By: **ECEM**  
 Report Date: **15 Jul 2025**

Sample ID: **S25-G02-039D** Sampling Date: **02 Jul 2025**  
 Sample Description: **N5** Sampling Time: **09:40 AM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @06:08PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:08PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>8</b>	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:36PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:08PM	AHP

Sample ID: **S25-G02-040D** Sampling Date: **02 Jul 2025**  
 Sample Description: **Deepwell 13** Sampling Time: **09:45 AM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @06:11PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:11PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:36PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:11PM	AHP

Sample ID: **S25-G02-041D** Sampling Date: **02 Jul 2025**  
 Sample Description: **SRCC Boston** Sampling Time: **09:49 AM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @06:14PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:14PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:36PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:14PM	AHP

Sample ID: **S25-G02-042D** Sampling Date: **02 Jul 2025**  
 Sample Description: **N4** Sampling Time: **09:55 AM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @06:17PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:17PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:36PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:17PM	AHP

Sample ID: **S25-G02-044D** Sampling Date: **02 Jul 2025**  
 Sample Description: **Tuffo Residence** Sampling Time: **10:11 AM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Quezon City**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @06:23PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:23PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>52</b>	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:36PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:23PM	AHP



# Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga  
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga  
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com  
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID: **S25-G02-045D** Sampling Date: **02 Jul 2025**  
 Sample Description: **Reservoir 1** Sampling Time: **10:16 AM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @06:29PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:29PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>1</b>	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:36PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:29PM	AHP

Sample ID: **S25-G02-046D** Sampling Date: **02 Jul 2025**  
 Sample Description: **N2** Sampling Time: **10:21 AM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @06:29PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:29PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>7</b>	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:36PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:29PM	AHP

Sample ID: **S25-G02-048D** Sampling Date: **02 Jul 2025**  
 Sample Description: **N5** Sampling Time: **10:31 AM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @06:35PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:35PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>2</b>	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:36PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:35PM	AHP

Sample ID: **S25-G02-050D** Sampling Date: **02 Jul 2025**  
 Sample Description: **S1** Sampling Time: **10:44 AM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @06:41PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:41PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>2</b>	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:36PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:41PM	AHP

Sample ID: **S25-G02-051D** Sampling Date: **02 Jul 2025**  
 Sample Description: **BNC Pawikan** Sampling Time: **10:50 AM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @06:46PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:46PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:36PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:46PM	AHP

Sample ID: **S25-G02-052D** Sampling Date: **02 Jul 2025**  
 Sample Description: **Villas** Sampling Time: **10:55 AM**  
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @06:47PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:47PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:36PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:47PM	AHP





# Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga  
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga  
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com  
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	<b>S25-G02-053D</b>	Sampling Date:	<b>02 Jul 2025</b>
Sample Description:	<b>BNC Back Door</b>	Sampling Time:	<b>10:59 AM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<i>E. coli</i>	Absent	MPN/100 ml	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @06:10PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 ml	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:50PM	AHP
Heterotrophic Plate Count (HPC)	213	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:36PM	AHP
Total Coliform	<1.1	MPN/100 ml	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @08:50PM	AHP

Sample ID:	<b>S25-G02-054D</b>	Sampling Date:	<b>02 Jul 2025</b>
Sample Description:	<b>Deepwell 5</b>	Sampling Time:	<b>11:05 AM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<i>E. coli</i>	Absent	MPN/100 ml	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jun 2025 @06:53PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 ml	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:53PM	AHP
Heterotrophic Plate Count (HPC)	56	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:36PM	AHP
Total Coliform	<1.1	MPN/100 ml	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @08:53PM	AHP

Sample ID:	<b>S25-G02-055D</b>	Sampling Date:	<b>02 Jul 2025</b>
Sample Description:	<b>Sports Center Common Area</b>	Sampling Time:	<b>11:11 AM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<i>E. coli</i>	Absent	MPN/100 ml	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jun 2025 @06:56PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 ml	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:56PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:36PM	AHP
Total Coliform	<1.1	MPN/100 ml	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @08:56PM	AHP

Sample ID:	<b>S25-G02-056D</b>	Sampling Date:	<b>02 Jul 2025</b>
Sample Description:	<b>Sports Center Kitchen</b>	Sampling Time:	<b>11:14 AM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<i>E. coli</i>	Absent	MPN/100 ml	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jun 2025 @06:59PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 ml	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @06:59PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:36PM	AHP
Total Coliform	<1.1	MPN/100 ml	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @08:59PM	AHP

Sample ID:	<b>S25-G02-057D</b>	Sampling Date:	<b>02 Jul 2025</b>
Sample Description:	<b>Golf Kitchen</b>	Sampling Time:	<b>11:35 AM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<i>E. coli</i>	Absent	MPN/100 ml	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jun 2025 @07:02PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 ml	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:02PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:36PM	AHP
Total Coliform	<1.1	MPN/100 ml	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:02PM	AHP

Sample ID:	<b>S25-G02-058D</b>	Sampling Date:	<b>02 Jul 2025</b>
Sample Description:	<b>Caddle</b>	Sampling Time:	<b>11:39 AM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<i>E. coli</i>	Absent	MPN/100 ml	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jun 2025 @07:05PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 ml	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:05PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:36PM	AHP
Total Coliform	<1.1	MPN/100 ml	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:05PM	AHP



# Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga  
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga  
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com  
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	<b>S25-G02-059D</b>	Sampling Date:	<b>02 Jul 2025</b>
Sample Description:	<b>Deepwell 8</b>	Sampling Time:	<b>11:45 AM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @07:08PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:08PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:38PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:08PM	AHP

Sample ID:	<b>S25-G02-060D</b>	Sampling Date:	<b>02 Jul 2025</b>
Sample Description:	<b>Deepwell 9</b>	Sampling Time:	<b>11:50 AM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @07:11PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:11PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:38PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:11PM	AHP

Sample ID:	<b>S25-G02-061D</b>	Sampling Date:	<b>02 Jul 2025</b>
Sample Description:	<b>N9</b>	Sampling Time:	<b>11:55 AM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @07:14PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:14PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>1</b>	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:38PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:14PM	AHP

Sample ID:	<b>S25-G02-062D</b>	Sampling Date:	<b>02 Jul 2025</b>
Sample Description:	<b>SBV Condo</b>	Sampling Time:	<b>11:59 AM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @07:17PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:17PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>6</b>	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:38PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:17PM	AHP

Sample ID:	<b>S25-G02-063D</b>	Sampling Date:	<b>02 Jul 2025</b>
Sample Description:	<b>Reservoir 2</b>	Sampling Time:	<b>12:08 PM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @07:20PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:20PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:38PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:20PM	AHP

Sample ID:	<b>S25-G02-064D</b>	Sampling Date:	<b>02 Jul 2025</b>
Sample Description:	<b>Deepwell 10</b>	Sampling Time:	<b>12:13 PM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<b>E.coli</b>	<b>Absent</b>	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @07:23PM	AHP
<b>Thermotolerant Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:23PM	AHP
<b>Heterotrophic Plate Count (HPC)</b>	<b>&lt;1</b>	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:38PM	AHP
<b>Total Coliform</b>	<b>&lt;1.1</b>	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:23PM	AHP



# Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga  
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga  
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com  
 Technical: 0917-507-8753 • 0917-164-2944

Sample ID:	<b>S25-G02-065D</b>	Sampling Date:	<b>02 Jul 2025</b>
Sample Description:	<b>NGB</b>	Sampling Time:	<b>12:17 PM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<i>E. coli</i>	Absent	MPN/100 mL	Absent	PASSED	MFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @07:28PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:28PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:28PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:28PM	AHP

Sample ID:	<b>S25-G02-066D</b>	Sampling Date:	<b>02 Jul 2025</b>
Sample Description:	<b>Deepwell 11</b>	Sampling Time:	<b>12:21 PM</b>
Sample Matrix:	<b>Drinking Water</b>	Sampling Location:	<b>Anvaya Cove, Morong, Bataan</b>

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
<i>E. coli</i>	Absent	MPN/100 mL	Absent	PASSED	MFT Thermotolerant Coliform Test (EC Medium)	02 Jul 2025 @07:28PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:28PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Jul 2025 @07:28PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Jul 2025 @07:28PM	AHP

### Notes & References:

Standard Methods for the Examination of Water and Wastewater, 24th Edition.  
 DOH Administrative Order No. 2017-0010, PMSDW 2017.

#### Certified by:

*Anita H. Pineda*  
 Anita H. Pineda, RMT  
 Chief Microbiologist, PRC No. 52546

#### Approved by:

*May Ann M. Estavillo*  
 May Ann M. Estavillo, RCh  
 General Manager, PRC No. 8652

Test results written in this report are based on the samples as received by the laboratory. No alteration or modification of this test report shall be binding against Echem unless in writing and signed by a duly authorized representative of the company. This report shall not be reproduced, except in full, without the written permission from the laboratory.

Not valid without  
 company seal