



Echem ENVIRONMENTAL TESTING LABORATORY CORPORATION

Laboratory: Blk 22 Lot 6A, Golden Sun 999 Ind'l Park, Quezon Rd., San Pablo Libutad, San Simon, Pampanga
 Satellite Office: G/F ASCORP Bldg., Mc Arthur Highway, Dolores, City of San Fernando, Pampanga
 Sales: 0942-316-2538 • 0945-798-6962 | (045) 435-2795 Email: echemenvironmental@gmail.com
 Technical: 0917-507-8753 • 0917-164-2944

DOH Accreditation No.03-010-2325-LW-2 Valid until December 31, 2025
 DENR C.R.No. 074/2023 Valid until June 24, 2026

TEST REPORT

Client: **Manila Water Philippine Ventures, Inc.**
 Address: **3rd Floor, UP Town Corporate Center, Katipunan, Quezon City**
 Contact Person: **Ms. Florisza Faustino**
 COC Number: **2025-10036**

Test Report No.: **TR-25I-250**
 Date and Time Received: **02 Sep 2025 @05:00PM**
 Sampled By: **ECHEM**
 Report Date: **16 Sep 2025**

Sample ID: **S25-I02-030D** Sampling Date: **02 Sep 2025**
 Sample Description: **N5** Sampling Time: **08:08 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2025 @07:01PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2025 @07:01PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2025 @08:37PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2025 @07:01PM	AHP

Sample ID: **S25-I02-031D** Sampling Date: **02 Sep 2025**
 Sample Description: **Deepwell 13** Sampling Time: **09:59 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2025 @07:04PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2025 @07:04PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2025 @08:37PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2025 @07:04PM	AHP

Sample ID: **S25-I02-032D** Sampling Date: **02 Sep 2025**
 Sample Description: **SRCC Boston** Sampling Time: **08:14 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2025 @07:07PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2025 @07:07PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2025 @08:37PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2025 @07:07PM	AHP

Sample ID: **S25-I02-033D** Sampling Date: **02 Sep 2025**
 Sample Description: **N4** Sampling Time: **08:19 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2025 @07:10PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2025 @07:10PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2025 @08:37PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2025 @07:10PM	AHP

Sample ID: **S25-I02-034D** Sampling Date: **02 Sep 2025**
 Sample Description: **N7** Sampling Time: **08:25 AM**
 Sample Matrix: **Drinking Water** Sampling Location: **Anvaya Cove, Morong, Bataan**

Parameter	Result	Unit	Limit	Remarks	Method	Date Analyzed	Analyst
E.coli	Absent	MPN/100 mL	Absent	PASSED	MTFT Thermotolerant Coliform Test (EC Medium)	02 Sep 2025 @07:13PM	AHP
Thermotolerant Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2025 @07:13PM	AHP
Heterotrophic Plate Count (HPC)	<1	CFU/mL	< 500	PASSED	Pour Plate	02 Sep 2025 @08:37PM	AHP
Total Coliform	<1.1	MPN/100 mL	< 1.1	PASSED	Multiple Tube Fermentation Technique	02 Sep 2025 @07:13PM	AHP